

LAB^{TQ}- MARCOGAZ Workshop

**Standards for Ecodesign lot 1 and lot 2-
where are we?**

**Part 2 Overview of the mandated work to be
done. Are standards ready?**

Point 5) mCHP's

**Brussels, May 3rd 2012
Joerg Endisch**

Power & Efficiencies according to prEN50465

Useful heat output at rated heat output of cogeneration space heater with supplementary heater disabled

$$P_{CHP100+Sup0},$$

useful heat output at rated heat output of cogeneration space heater with supplementary heater enabled

$$P_{CHP100+Sup100},$$

Useful efficiency at rated heat output of cogeneration space heater with supplementary heater disabled

$$\eta_{CHP100+Sup0},$$

Useful efficiency at rated heat output of cogeneration space heater with supplementary heater enabled

$$\eta_{CHP100+Sup100},$$

Electrical efficiency at rated heat output of cogeneration space heater with supplementary heater disabled

$$\eta_{el,CHP100+Sup0},$$

Electrical efficiency at rated heat output of cogeneration space heater with supplementary heater enabled

$$\eta_{el,CHP100+Sup100}$$

based on document: 7_WD_Testing Calculation Space and Combi Heater-2-2-12

1 - what are the parameters to be measured

Standby heat loss P_{stby}

EN15502-1, § 9.3.2.3.1.3
Standby losses (test)

**Ignition burner power
consumption P_{ign}**

EN15502-1, § 9.3.2
Q3 = permanent ign.burner

**Emission of nitrogen
oxides NO_x**

EN15502-1 § 8.13.
NO_x (classification, test- and
calculation methods)

1 - what are the parameters to be measured

Seasonal space heating energy efficiency

$$\eta_s = \eta_{son} - \sum F(i)$$

$$\begin{aligned} \eta_{son} &= \eta_{CHP100+Sup0} \\ &= 0,85 \cdot \eta_{CHP100+Sup0} + 0,15 \cdot \eta_{CHP100+Sup100} \end{aligned}$$

$$F(1) = 3\% \quad (\text{contribution of controls "+"})$$

$$\begin{aligned} F(2) &= 2,5 \cdot (el_{max} + 1,3 \cdot PSB) / P_{CHP100+Sup0} \quad (\text{electr.aux "-"}) \\ &= 2,5 \cdot (0,15 \cdot el_{max} + 0,85 \cdot el_{min} + 1,3 \cdot PSB) / (0,15 \cdot \eta_{CHP100+Sup100} + 0,85 \cdot \eta_{CHP100+Sup0}) \end{aligned}$$

$$\begin{aligned} F(3) &= 0,5 \cdot P_{stby} / P_{CHP100+Sup0} \quad (\text{stdby loss "-"}) \\ &= 0,5 \cdot P_{stby} / P_{CHP100+Sup100} \end{aligned}$$

$$\begin{aligned} F(4) &= 0,5 \cdot P_{ign} / P_{CHP100+Sup0} \quad (\text{ign.burner "-"}) \\ &= 0,5 \cdot P_{ign} / P_{CHP100+Sup100} \end{aligned}$$

$$\begin{aligned} F(5) &= -2,5 \cdot \eta_{el,CHP100+Sup0} \quad (\text{electr. eff "+"}) \\ &= -2,5 \cdot (0,85 \cdot \eta_{el,CHP100+Sup0} + 0,15 \cdot \eta_{el,CHP100+Sup100}) \end{aligned}$$

- CEN/CLC/JWG/FCGA → prEN50465:2011(July)
- compiled comments are in discussion in the JWG
 - Items concerning efficiency, stdby, NOx still under discussion
 - final meeting October 2012
 - Power and efficiencies measurements = prEN50465, 7.6 ff
 - Stand-by losses: not yet in prEN50465, proposals to integrate requirements still to be discussed, are different to EuP paper, proposals do consider electrical energy production during stdby, reconsider status stand-by to cover all situations (e.g. keeping a fuel cell on temperature, see IEC62282-x)
 - NOx: prEN50465 is different from proposal in EuP paper (15502-1) to consider the CHP part and production of electricity

3 – what is the testing reproducibility expected?

- ➔ Thermal and Electrical input/output similar to existing standards, see EN15502-x or electrical appliances, requirements on measurement equipment corresponding to existing application
- ➔ Testing results strongly depending on temperature control and heat management controls as well as on involvement of thermal storage into management concept and on applied operation cycles / operation modes
- ➔ Testing results depending on definition of location of test points

4- is there some action needed to help the preparation/ improvement / updating of the standard

- ➔ EN50465 is elaborated by JWG
- ➔ experimental independent experience may ease work on testing conditions